



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-06-00615

Received Date: 06/04/2021
Reported Date: 06/30/2021
Sampled By: Sean Hanley
Tech Certification #:

Project/Test Address: 2020L-120.2; Franklinville Elementary School; 32 North Main Street;
Franklinville, NY 14737

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-00615-001	120.2-10	05/26/2021	ROOM 114 BATHROOM	4.14	06/29/2021	
21-06-00615-002	120.2-60	05/26/2021	ROOM 213 LEFT	34.8	06/29/2021	
21-06-00615-003	120.2-62	05/26/2021	ROOM 217	52.3	06/29/2021	
21-06-00615-004	120.2-77	05/26/2021	ROOM 308	25.0	06/29/2021	
21-06-00615-005	120.2-79	05/26/2021	ROOM 309	11.4	06/29/2021	
21-06-00615-006	120.2-97	05/26/2021	ROOM 218	10.5	06/29/2021	
21-06-00615-007	120.2-98	05/26/2021	ROOM 212	74.4	06/29/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-06-00615

Project/Test Address: 2020L-120.2; Franklinville Elementary School; 32 North Main Street; Franklinville, NY 14737

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	--------------

Method: EPA 200.8
Analyst: Anthony Dee
Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion
