

December 21, 2020

Dustin Brisky
Director of Facilities
Franklinville Central School District
31 North Main Street
Franklinville, NY 14737

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Brisky:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Franklinville Central School District, including:

- Jr./Sr. High School – 31 North Main Street, Franklinville, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on October 27, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 11 sources of potable water in the Jr./Sr. High School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Franklinville Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

Franklinville Central School District

Prepared by:



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Conditions as of October 27, 2020

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Franklinville Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Jr./Sr. High School – 31 North Main Street, Franklinville, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Jr./Sr. High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Jr./Sr. High School	10/27/2020	82	71	11	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
120.1-6	Concession Hand Wash	Sink	19.5
120.1-13	Athletic Storage Sink	Sink	106
120.1-15	Boys Locker Room Left	Sink	21.7
120.1-16	Boys Locker Room Right	Sink	17.5
120.1-19	Room 008 Right	Sink	30.8
120.1-22	Room 009 Right	Sink	16.7
120.1-28	Front Kitchen Line Hand Wash	Sink	16.8
120.1-32	Kitchen Hand Wash	Sink	86.3
120.1-37	Kitchen Dish Area Hand Wash	Sink	51.4
120.1-50	Basement Art Left	Sink	26.5
120.1-61	Girls Bathroom Middle	Sink	15.4

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 20-11-01895

Received Date: 11/12/2020
Reported Date: 12/03/2020
Sampled By: Andrew White
Tech Certification #:

Project/Test Address: 2020L-120.1; Franklinville Jr/Sr High School; 31 North Main Street;
Franklinville, NY 14737

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-11-01895-001	120.1-1	10/27/2020	MENS BATH LEFT BY GYM	2.56	12/02/2020	
20-11-01895-002	120.1-2	10/27/2020	MENS BATH RIGHT BY GYM	3.82	12/01/2020	
20-11-01895-003	120.1-3	10/27/2020	GIRLS BATH LEFT BY GYM	5.91	12/01/2020	
20-11-01895-004	120.1-4	10/27/2020	GIRLS BATH RIGHT BY GYM	2.09	12/02/2020	
20-11-01895-005	120.1-5A	10/27/2020	DRINKING FOUNTAIN NEAR GYM	<1.00	12/01/2020	
20-11-01895-006	120.1-5B	10/27/2020	BOTTLE FILL NEAR GYM	<1.00	12/01/2020	
20-11-01895-007	120.1-6	10/27/2020	CONCESSION HAND WASH	19.5	12/01/2020	
20-11-01895-008	120.1-7	10/27/2020	CONCESSION TRIPLE	2.81	12/01/2020	
20-11-01895-009	120.1-8	10/27/2020	AG SHOP LEFT	5.78	12/01/2020	
20-11-01895-010	120.1-9	10/27/2020	AG SHOP RIGHT	3.99	12/01/2020	
20-11-01895-011	120.1-10	10/27/2020	GIRLS LOCKER ROOM LEFT	1.98	12/01/2020	
20-11-01895-012	120.1-11	10/27/2020	GIRLS LOCKER ROOM MIDLE	1.72	12/01/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-11-01895

Project/Test Address: 2020L-120.1; Franklinville Jr/Sr High School; 31 North Main Street; Franklinville, NY 14737

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-11-01895-013	120.1-12	10/27/2020	GIRLS LOCKER ROOM RIGHT	1.76	12/01/2020	
20-11-01895-014	120.1-13	10/27/2020	ATHLETIC STROAGE SINK	106	12/01/2020	
20-11-01895-015	120.1-14	10/27/2020	ATHLETIC STORAGE ICE	<1.00	12/02/2020	
20-11-01895-016	120.1-15	10/27/2020	BOYS LOCKER ROOM LEFT	21.7	12/01/2020	
20-11-01895-017	120.1-16	10/27/2020	BOYS LOCKER ROOM RIGHT	17.5	12/01/2020	
20-11-01895-018	120.1-17A	10/27/2020	OUTSIDE LOCKER ROOM FOUNTAIN	<1.00	12/01/2020	
20-11-01895-019	120.1-17B	10/27/2020	OUTSIDE LOCKER ROOM BOTTLE FILL	<1.00	12/01/2020	
20-11-01895-020	120.1-18	10/27/2020	ROOM 008 LEFT	14.3	12/01/2020	
20-11-01895-021	120.1-19	10/27/2020	ROOM 008 RIGHT	30.8	12/01/2020	
20-11-01895-022	120.1-20	10/27/2020	ROOM 009 LEFT	10.1	12/01/2020	
20-11-01895-023	120.1-21	10/27/2020	ROOM 009 MIDDLE	14.9	12/01/2020	
20-11-01895-024	120.1-22	10/27/2020	ROOM 009 RIGHT	16.7	12/01/2020	
20-11-01895-025	120.1-23	10/27/2020	1ST FLOOR ATHLETIC HALL BOYS LEFT	6.65	12/01/2020	
20-11-01895-026	120.1-24	10/27/2020	1ST FLOOR ATHELTIC HALL BOYS RIGHT	4.56	12/01/2020	
20-11-01895-027	120.1-25	10/27/2020	1ST FLOOR ATHLETIC HALL GIRLS LEFT	4.62	12/01/2020	
20-11-01895-028	120.1-26	10/27/2020	1ST FLOOR ATHLETIC HALL GIRLS RIGHT	4.55	12/01/2020	
20-11-01895-029	120.1-27A	10/27/2020	CAFE DRINKING FOUNTAIN	<1.00	12/01/2020	
20-11-01895-030	120.1-27B	10/27/2020	CAFE BOTTLE FILL	<1.00	12/01/2020	
20-11-01895-031	120.1-28	10/27/2020	FRONT KITCHEN LINE HAND WASH	16.8	12/01/2020	
20-11-01895-032	120.1-29	10/27/2020	FRONT KITCHEN LINE PREP	11.4	12/02/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-11-01895

Project/Test Address: 2020L-120.1; Franklinville Jr/Sr High School; 31 North Main Street; Franklinville, NY 14737

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-11-01895-033	120.1-30	10/27/2020	FRONT KITCHEN LINE ICE	<1.00	12/01/2020	
20-11-01895-034	120.1-31	10/27/2020	KITCHEN KETTLE FILL	4.80	12/01/2020	
20-11-01895-035	120.1-32	10/27/2020	KITCHEN HAND WASH	86.3	12/01/2020	
20-11-01895-036	120.1-33	10/27/2020	KITCHEN ISLAND PREP	2.37	12/01/2020	
20-11-01895-037	120.1-34	10/27/2020	KITCHEN BACK PREP	2.75	12/01/2020	
20-11-01895-038	120.1-35	10/27/2020	KITCHEN TRIPLE SINK	6.60	12/01/2020	
20-11-01895-039	120.1-36	10/27/2020	KITCHEN DISH WAND	4.39	12/01/2020	
20-11-01895-040	120.1-37	10/27/2020	KITCHEN DISH AREA HAND WASH	51.4	12/01/2020	
20-11-01895-041	120.1-38	10/27/2020	FACULTY MAIN	1.62	12/01/2020	
20-11-01895-042	120.1-39	10/27/2020	FACULTY BATH	1.53	12/02/2020	
20-11-01895-043	120.1-40A	10/27/2020	ROOM 112 FOUNTAIN	<1.00	12/01/2020	
20-11-01895-044	120.1-40B	10/27/2020	ROOM 112 BOTTLE FILL	<1.00	12/01/2020	
20-11-01895-045	120.1-41	10/27/2020	WOMENS FIRST FLOOR SINGLE BATH	2.21	12/01/2020	
20-11-01895-046	120.1-42	10/27/2020	WOMENS FIRST FLOOR LEFT	1.55	12/02/2020	
20-11-01895-047	120.1-43	10/27/2020	WOMEN'S FIRST FLOOR RIGHT	2.26	12/02/2020	
20-11-01895-048	120.1-44	10/27/2020	ROOM 115 SINK	2.87	12/02/2020	
20-11-01895-049	120.1-45	10/27/2020	ROOM 115 FOUNTAIN	1.63	12/02/2020	
20-11-01895-050	120.1-46	10/27/2020	ROOM 113 SINK	12.7	12/02/2020	
20-11-01895-051	120.1-47	10/27/2020	ROOM 113 FOUNTAIN	1.51	12/02/2020	
20-11-01895-052	120.1-48	10/27/2020	NURSE BATH	5.33	12/02/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-11-01895

Project/Test Address: 2020L-120.1; Franklinville Jr/Sr High School; 31 North Main Street; Franklinville, NY 14737

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-11-01895-053	120.1-49	10/27/2020	NURSE MAIN	6.93	12/02/2020	
20-11-01895-054	120.1-50	10/27/2020	BASEMENT ART LEFT	26.5	12/02/2020	
20-11-01895-055	120.1-51	10/27/2020	BASEMENT ART RIGHT	8.15	12/02/2020	
20-11-01895-056	120.1-52	10/27/2020	BASEMENT GUYS BATH	6.25	12/02/2020	
20-11-01895-057	120.1-53	10/27/2020	BASEMENT GIRLS BATH	6.30	12/02/2020	
20-11-01895-058	120.1-54	10/27/2020	MAIN ART LEFT 120	2.25	12/02/2020	
20-11-01895-059	120.1-55	10/27/2020	MAIN ART RIGHT 120	2.39	12/02/2020	
20-11-01895-060	120.1-56	10/27/2020	NEAR ART WOMENS BATH	1.81	12/02/2020	
20-11-01895-061	120.1-57	10/27/2020	NEAR ART MENS BATH	2.64	12/02/2020	
20-11-01895-062	120.1-58	10/27/2020	2ND FLOOR STAFF BATH	2.07	12/02/2020	
20-11-01895-063	120.1-59	10/27/2020	2ND FLOOR PRIVATE BATH	2.65	12/02/2020	
20-11-01895-064	120.1-60	10/27/2020	GIRLS BATH LEFT	3.53	12/02/2020	
20-11-01895-065	120.1-61	10/27/2020	GIRLS BATH MIDDLE	15.4	12/02/2020	
20-11-01895-066	120.1-62	10/27/2020	GIRLS BATH RIGHT	7.74	12/02/2020	
20-11-01895-067	120.1-63	10/27/2020	BOYS BATH LEFT	6.43	12/02/2020	
20-11-01895-068	120.1-64	10/27/2020	BOYS BATH MIDDLE	7.19	12/02/2020	
20-11-01895-069	120.1-65	10/27/2020	BOYS BATH RIGHT	7.04	12/02/2020	
20-11-01895-070	120.1-66	10/27/2020	222 UPPER FOUNTAIN	<1.00	12/02/2020	
20-11-01895-071	120.1-67	10/27/2020	222 LOWER FOUNTAIN	<1.00	12/02/2020	
20-11-01895-072	120.1-68	10/27/2020	ACROSS 213 FOUNTAIN	<1.00	12/02/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-11-01895


Project/Test Address: 2020L-120.1; Franklinville Jr/Sr High School; 31 North Main Street; Franklinville, NY 14737

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-11-01895-073	120.1-69	10/27/2020	BOY GIRL BATH ACROSS 69	1.44	12/02/2020	
20-11-01895-074	120.1-70	10/27/2020	GIRLS BATH LEFT ACROSS 213	1.80	12/02/2020	
20-11-01895-075	120.1-71	10/27/2020	GIRLS BATH RIGHT ACROSS 213	2.40	12/02/2020	
20-11-01895-076	120.1-72	10/27/2020	LG BACK OFFICE	4.99	12/02/2020	
20-11-01895-077	120.1-73	10/27/2020	FACULTY WORKROOM	5.46	12/02/2020	
20-11-01895-078	120.1-74A	10/27/2020	319 FOUNTAIN	<1.00	12/02/2020	
20-11-01895-079	120.1-74B	10/27/2020	319 BOTTLE FILL	<1.00	12/02/2020	
20-11-01895-080	120.1-75	10/27/2020	ACROSS 319 BOYS BATH	1.23	12/02/2020	
20-11-01895-081	120.1-76	10/27/2020	ACROSS 319 GIRLS LEFT	1.13	12/02/2020	
20-11-01895-082	120.1-77	10/27/2020	ACROSS 319 GIRLS RIGHT	1.39	12/02/2020	

Method: SM 3113B-2010

Analyst: Jennalee Hertzler

Accreditation #: NY 11714

Reviewed By Authorized Signatory: 

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2021
Issued April 01, 2020

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Copper, Total SM 19, 21-23 3113B (-04,-10)

Lead, Total SM 19, 21-23 3113B (-04,-10)



Department
of Health

Serial No.: 61514

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-120.1

Client: Franklinville CSD

Contact: Dustin Brisky

Building: Franklinville Jr./Sr. High School

Location: 31 North Main Street Franklinville, NY 14737

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
120.1-1	Men's bath left by gym	Sink	21:20			
120.1-2	Men's bath right by gym	Sink	21:21			
120.1-3	Girls bath left by gyn	Sink	21:22			
120.1-4	Girls bath right by gym	Aink	21:23			
120.1-5A	Drinking fountain near gym	DF	21:24			
120.1-5B	Bottle fill near gym	DFB	21:25			
120.1-6	Concession hand wash	Sink	21:26			
120.1-7	Concession triple	Sink	21:27			
120.1-8	Ag shop left	Sink	21:28			
120.1-9	Ag shop right	Sink	21:29			
120.1-10	Girls locker room left	Sink	21:30			
120.1-11	Girls locker room middle	Sink	21:31			
120.1-12	Girls locker room right	Sink	21:32			
120.1-13	Athletic storage aink	Sink	21:33			
120.1-14	Athletic storage ice	IM	21:34			
120.1-15	Boys locker room left	Sink	21:35			
120.1-16	Boys locker room rig	Sink	21:36			
120.1-17A	Outside locker room fountain	DF	21:37			

20-11-01895



Due Date:
 12/11/2020
 (Friday)
 AE

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Andrew White Print Name Andrew White Stohl Env: Andrew White Date: 10/27/2020

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 11/4/2020

Received (Name / Lab): K. Harris Date: 11/12/20 Time: 2:53pm

Sample Login (Name / Lab): Lian Bom Date: 11/19/20 Time: 4:51PM

Analysis (Name / Lab): J. Hertgen Date: 12/2/20 Time: 5:30pm

QA/QC Review (Name / Lab): M. Huse Date: 12/3/20 Time: 10am

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLNENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-120.1

Client: Franklinville CSD

Contact: Dustin Brisky

Building: Franklinville Jr./Sr. High School

Location: 31 North Main Street Franklinville, NY 14737

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
120.1-17B	Outside locker room bottle fill	DFB	21:38			
120.1-18	Room 008 left	Sink	21:39			
120.1-19	Room 008 right	Sink	21:40			
120.1-20	Room 009 left	Sink	21:41			
120.1-21	Room 009 middle	Sink	21:42			
120.1-22	Room 009 right	Sink	21:43			
120.1-23	1st floor athletic hall boys left	Sink	21:44			
120.1-24	1st floor athletic hall ohs right	Sink	21:45			
120.1-25	1st floor athletic hall girls left	Sink	21:46			
120.1-26	1st floor athletic hall girls right	Sink	21:47			
120.1-27A	Cafe drinking fountain	DF	21:48			
120.1-27B	Cafe bottle fill	DFB	21:49			
120.1-28	Front kitchen line hand wash	Sink	21:50			
120.1-29	Front kitchen line prep	Sink	21:51			
120.1-30	Front kitchen line ice	IM	21:52			
120.1-31	Kitchen kettle fill	Sink	21:53			
120.1-32	Kitchen hand wash	Sink	21:54			
120.1-33	Kitchen island prep	Sink	21:55			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Andrew White Print Name Stohl Env: Andrew White Date: 10/27/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 11/4/2020

Received (Name / Lab): RETHARRIS Date: 11/19/20 Time: 2:53 pm

Sample Login (Name / Lab): Shari B... Date: 11/19/20 Time: 4:53 PM

Analysis (Name / Lab): J. Hertzler Date: 12/2/20 Time: 5:30 pm

QA/QC Review (Name / Lab): Mel... Date: 12/3/20 Time: 10am

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-120.1

Client: Franklinville CSD

Contact: Dustin Brisky

Building: Franklinville Jr./Sr. High School

Location: 31 North Main Street Franklinville, NY 14737

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
120.1-34	Kitchen back prep	Sink	21:56			
120.1-35	Kitchen triple sink	Sink	21:57			
120.1-36	Kitchen dish wand	Sink	21:58			
120.1-37	Kitchen dish area hand wash	Sink	21:59			
120.1-38	Faculty main	Sink	22:00			
120.1-39	Faculty bath	Sink	22:01			
120.1-40A	Room 112 fountain	DF	22:02			
120.1-40B	Room 112 bottle fill	DFB	22:03			
120.1-41	Women's first floor single bath	Sink	22:04			
120.1-42	Women's first floor left	Sink	22:05			
120.1-43	Women's first floor right	Sink	22:06			
120.1-44	Room 115 sink	Sink	22:07			
120.1-45	Room 115 fountain	Df	22:08			
120.1-46	Room 113 sink	Sink	22:09			
120.1-47	Room 113 fountain	Df	22:10			
120.1-48	Nurse bath	Sink	22:11			
120.1-49	Nurse main	Sink	22:12			
120.1-50	Basement art left	Sink	22:13			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Andrew White Print Name Stohl Env: Andrew White Date: 10/27/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 11/4/2020

Received (Name / Lab): KT Harris Date: 11/12/20 Time: 2:53 pm

Sample Login (Name / Lab): Paul Blom Date: 11/19/20 Time: 4:54 PM

Analysis (Name / Lab): J. Vertigler Date: 12/2/20 Time: 5:30 pm

QA/QC Review (Name / Lab): Melinda Date: 12/3/20 Time: 1:00 am

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-120.1

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Client: Franklinville CSD

Contact: Dustin Brisky

Building: Franklinville Jr./Sr. High School

Location: 31 North Main Street Franklinville, NY 14737

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
120.1-51	Basement art right	Sink	22:14			
120.1-52	Basement guys bath	Sink	22:15			
120.1-53	Basement girls bath	Sink	22:16			
120.1-54	Main art left 120	Sink	22:17			
120.1-55	Main art right 120	Sink	22:18			
120.1-56	Near art women's bath	Sink	22:19			
120.1-57	Near art men's bath	Sink	22:20			
120.1-58	2nd floor staff bath	Sink	22:21			
120.1-59	2nd floor private bath	Sink	22:22			
120.1-60	Girls bath left	Sink	22:23			
120.1-61	Girls bath middle	Sink	22:24			
120.1-62	Girls bath right	Sink	22:25			
120.1-63	Boys bath left	Sink	22:26			
120.1-64	Boys bath middle	Sink	22:27			
120.1-65	Boys bath right	Sink	22:28			
120.1-66	222 upper fountain	DF	22:29			
120.1-67	222 lower fountain	DF	22:30			
120.1-68	Across 213 fountain	DF	22:31			

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Andrew White Print Name Stohl Env: Andrew White Date: 10/27/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 11/4/2020

Received (Name / Lab): K. HARRIS Date: 11/12/20 Time: 2:53 pm

Sample Login (Name / Lab): Thaci Blom Date: 11/19/20 Time: 4:55 PM

Analysis (Name / Lab): G. Henderson Date: 12/2/20 Time: 5:30 pm

QA/QC Review (Name / Lab): Melissa Date: 12/3/20 Time: 10am

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



STOHL Job # 2020L-120.1

Location: 31 North Main Street Franklinville, NY 14737

20 Days

Please e-mail lab results to labs@stohlenv.com

Page 5 of 5

BLANK

BLANK

BLANK



3860 California Road, Orchard Park, New York 14127

PHONE (716) 312-0070 FAX (716) 312-8092

WWW.STOHLENVIRONMENTAL.COM